

**DMR Copy of Record**

<b>Permit</b>			
Permit #:	IL0022471	Permittee:	GLENBARD WASTEWATER AUTHORITY
Major:	No	Permittee Address:	954 BEMIS RD GLEN ELLYN, IL 60137
Permitted Feature:	001 External Outfall	Discharge:	001-0 COMBINED SEWAGE TREATMENT FACILITY
Facility:	GWA CSO STORMWATER FACILITY		Facility Location:
		ILLINOIS ROUTE 53 AND HILL AVE LOMBARD, IL 60148	

<b>Report Dates &amp; Status</b>			
Monitoring Period:	From 04/01/20 to 04/30/20	DMR Due Date:	05/25/20
Status:	NetDMR Validated		

**Considerations for Form Completion**  
 BOW ID: W0430600002; NUMBER OF DAYS OF DISCHARGE:

<b>Principal Executive Officer</b>			
First Name:	Matt	Title:	Executive Director
Last Name:	Streicher	Telephone:	630-790-1901

**No Data Indicator (NODI)**  
 Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type			
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3				Value 3	Units	
00310	BOD, 5-day, 20 deg. C	1 - Effluent Gross	0	--	Sample						=	65.7				19 - mg/L	0	DL/DS - Daily When Discharging	GR - GRAB	
					Permit Req.							Req Mon MO AVG				19 - mg/L				
					Value NODI															
00400	pH	1 - Effluent Gross	0	--	Sample						=	7.74			12 - SU	0	DL/DS - Daily When Discharging	GR - GRAB		
					Permit Req.						>=	6.0 MINIMUM			<=				9.0 MAXIMUM	12 - SU
					Value NODI															
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample						=	36.0			19 - mg/L	0	DL/DS - Daily When Discharging	GR - GRAB		
					Permit Req.							Req Mon MO AVG							19 - mg/L	
					Value NODI															
00665	Phosphorus, total [as P]	1 - Effluent Gross	0	--	Sample						=	1.18			19 - mg/L	0	DL/DS - Daily When Discharging	GR - GRAB		
					Permit Req.							Req Mon DAILY MX							19 - mg/L	
					Value NODI															
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample						=	0.09			19 - mg/L	0	DL/DS - Daily When Discharging	GR - GRAB		
					Permit Req.						<=	0.75 MO AVG							19 - mg/L	
					Value NODI															
74055	Coliform, fecal general	1 - Effluent Gross	0	--	Sample						=	4.0			13 - #/100mL	0	DL/DS - Daily When Discharging	GR - GRAB		
					Permit Req.						<=	400.0 DAILY MX							13 - #/100mL	
					Value NODI															
82220	Flow, total	1 - Effluent Gross	0	--	Sample			=	55.13	80 - Mgal/mo					0	DL/DS - Daily When Discharging	CN - CONTIN			
					Permit Req.				Req Mon MO TOTAL	80 - Mgal/mo										
					Value NODI															

**Submission Note**  
 If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

**Edit Check Errors**  
 No errors.

**Comments**  
 3 days of Discharging

**Attachments**  
 No attachments.

**Report Last Saved By**  
 GLENBARD WASTEWATER AUTHORITY

User: PETERSDAVID  
 Name: David Peters  
 E-Mail: dpeters@gbww.org  
 Date/Time: 2020-05-12 11:05 (Time Zone: -05:00)

**Report Last Signed By**  
 User: PETERSDAVID

Name: David Peters  
E-Mail: dpeters@gbww.org  
Date/Time: 2020-05-12 11:05 (Time Zone: -05:00)