

00625	Nitrogen, Kjeldahl, total [as N]	1 - Effluent Gross	0	--	Permit Req.												Req Mon DAILY MX	19 - mg/L	01/30 - Monthly	CP - COMPOS		
					Value NODI												B - Below Detection Limit/No Detection					
00630	Nitrite + Nitrate total [as N]	1 - Effluent Gross	0	--	Sample						=	30.3					30.3	19 - mg/L	01/30 - Monthly	CP - COMPOS		
					Permit Req.												Req Mon DAILY MX	19 - mg/L	0	01/30 - Monthly	CP - COMPOS	
					Value NODI																	
00665	Phosphorus, total [as P]	1 - Effluent Gross	0	--	Sample						=	2.68					3.16	19 - mg/L	01/07 - Weekly	CP - COMPOS		
					Permit Req.												Req Mon MO AVG	19 - mg/L	0	01/07 - Weekly	CP - COMPOS	
					Value NODI																	
00666	Phosphorus, dissolved	1 - Effluent Gross	0	--	Sample						=	2.64					2.64	19 - mg/L	01/30 - Monthly	CP - COMPOS		
					Permit Req.												Req Mon DAILY MX	19 - mg/L	0	01/30 - Monthly	CP - COMPOS	
					Value NODI																	
00940	Chloride [as Cl]	1 - Effluent Gross	0	--	Sample						=	110.0					110.0	19 - mg/L	01/30 - Monthly	GR - GRAB		
					Permit Req.												Req Mon DAILY MX	19 - mg/L	0	01/30 - Monthly	GR - GRAB	
					Value NODI																	
30500	Coliform, fecal - % samples exceeding limit	1 - Effluent Gross	0	--	Sample						=	0.0					0.0	23 - %	02/DA - 2 Days Every Week	GR - GRAB		
					Permit Req.						<=	10.0 MAXIMUM					10.0 MAXIMUM	23 - %	0	02/DA - 2 Days Every Week	GR - GRAB	
					Value NODI																	
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	8.17	=	19.44	03 - MGD											99/99 - Continuous	
					Permit Req.		Req Mon MO AVG		Req Mon DAILY MX	03 - MGD												99/99 - Continuous
					Value NODI																	
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample						=	0.0					0.0	19 - mg/L	0	CL/OC - Chlorination/Occurances	GR - GRAB	
					Permit Req.						<=	0.038 DAILY MX					0.038 DAILY MX	19 - mg/L	0	CL/OC - Chlorination/Occurances	GR - GRAB	
					Value NODI																	
74055	Coliform, fecal general	1 - Effluent Gross	0	--	Sample						=	2.31					20.0	13 - #/100mL	02/DA - 2 Days Every Week	GR - GRAB		
					Permit Req.						<=	200.0 GEO MEAN					Req Mon DAILY MX	13 - #/100mL	0	02/DA - 2 Days Every Week	GR - GRAB	
					Value NODI																	
80082	BOD, carbonaceous [5 day, 20 C]	1 - Effluent Gross	0	--	Sample	=	263.27	=	1118.69	26 - lb/d							3.18	19 - mg/L	02/DA - 2 Days Every Week	CP - COMPOS		
					Permit Req.	<=	3920.0 MO AVG	<=	7840.0 DAILY MX	26 - lb/d							10.0 MO AVG	19 - mg/L	0	02/DA - 2 Days Every Week	CP - COMPOS	
					Value NODI												20.0 DAILY MX					

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

No attachments.

Report Last Saved By

GLENBARD WASTEWATER AUTHORITY

User: PETERSDAVID
 Name: David Peters
 E-Mail: dpeters@gbww.org
 Date/Time: 2024-08-12 13:06 (Time Zone: -05:00)

Report Last Signed By

User: PETERSDAVID
 Name: David Peters
 E-Mail: dpeters@gbww.org

