

00625	Nitrogen, Kjeldahl, total [as N]	1 - Effluent Gross	0	--	Permit Req.														Req Mon DAILY MX	19 - mg/L		01/30 - Monthly	CP - COMPOS				
					Value NODI														B - Below Detection Limit/No Detection								
00630	Nitrite + Nitrate total [as N]	1 - Effluent Gross	0	--	Sample														=	38.4	19 - mg/L		01/30 - Monthly	CP - COMPOS			
					Permit Req.															Req Mon DAILY MX	19 - mg/L	0	01/30 - Monthly	CP - COMPOS			
					Value NODI																						
00665	Phosphorus, total [as P]	1 - Effluent Gross	0	--	Sample														=	3.58			01/07 - Weekly	CP - COMPOS			
					Permit Req.															Req Mon MO AVG	Req Mon DAILY MX	19 - mg/L	0	01/07 - Weekly	CP - COMPOS		
					Value NODI																						
00666	Phosphorus, dissolved	1 - Effluent Gross	0	--	Sample														=	3.4	19 - mg/L		01/30 - Monthly	CP - COMPOS			
					Permit Req.															Req Mon DAILY MX	19 - mg/L	0	01/30 - Monthly	CP - COMPOS			
					Value NODI																						
00940	Chloride [as Cl]	1 - Effluent Gross	0	--	Sample														=	111.0	19 - mg/L		01/30 - Monthly	GR - GRAB			
					Permit Req.															Req Mon DAILY MX	19 - mg/L	0	01/30 - Monthly	GR - GRAB			
					Value NODI																						
30500	Coliform, fecal - % samples exceeding limit	1 - Effluent Gross	0	--	Sample														=	0.0	23 - %		02/DA - 2 Days Every Week	GR - GRAB			
					Permit Req.															<=	10.0 MAXIMUM	23 - %	0	02/DA - 2 Days Every Week	GR - GRAB		
					Value NODI																						
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	7.17	=	10.91	03 - MGD														99/99 - Continuous			
					Permit Req.		Req Mon MO AVG		Req Mon DAILY MX	03 - MGD													0	99/99 - Continuous			
					Value NODI																						
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample														=	0.0	19 - mg/L		CL/OC - Chlorination/Occurances	GR - GRAB			
					Permit Req.															<=	0.038 DAILY MX	19 - mg/L	0	CL/OC - Chlorination/Occurances	GR - GRAB		
					Value NODI																						
74055	Coliform, fecal general	1 - Effluent Gross	0	--	Sample														=	24.25			13 - #/100mL	02/DA - 2 Days Every Week	GR - GRAB		
					Permit Req.															<=	200.0 GEO MEAN	Req Mon DAILY MX	13 - #/100mL	0	02/DA - 2 Days Every Week	GR - GRAB	
					Value NODI																						
80082	BOD, carbonaceous [5 day, 20 C]	1 - Effluent Gross	0	--	Sample	=	121.17	=	320.49	26 - lb/d										=	2.18			19 - mg/L	02/DA - 2 Days Every Week	CP - COMPOS	
					Permit Req.	<=	3920.0 MO AVG	<=	7840.0 DAILY MX	26 - lb/d										<=	10.0 MO AVG	<=	20.0 DAILY MX	19 - mg/L	0	02/DA - 2 Days Every Week	CP - COMPOS
					Value NODI																						

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

No attachments.

Report Last Saved By

GLENBARD WASTEWATER AUTHORITY

User: PETERSDAVID
 Name: David Peters
 E-Mail: dpeters@gbww.org
 Date/Time: 2024-09-16 13:07 (Time Zone: -05:00)

Report Last Signed By

User: PETERSDAVID
 Name: David Peters
 E-Mail: dpeters@gbww.org

