

					Value NODI																		
00666	Phosphorus, dissolved	1 - Effluent Gross	0	--	Sample																		
					Permit Req.																		
					Value NODI																		
00940	Chloride [as Cl]	1 - Effluent Gross	0	--	Sample																		
					Permit Req.																		
					Value NODI																		
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	8.56	=	18.28	03 - MGD													
					Permit Req.																		
					Value NODI																		
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample																		
					Permit Req.																		
					Value NODI																		
80082	BOD, carbonaceous [5 day, 20 C]	1 - Effluent Gross	0	--	Sample	=	235.01	=	319.37	26 - lb/d													
					Permit Req.	<=	3920.0 MO AVG	<=	7840.0 DAILY MX	26 - lb/d													
					Value NODI																		

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

No attachments.

Report Last Saved By

GLENBARD WASTEWATER AUTHORITY

User: PETERSDAVID
 Name: David Peters
 E-Mail: dpeters@gbww.org
 Date/Time: 2025-02-10 13:16 (Time Zone: -06:00)

Report Last Signed By

User: PETERSDAVID
 Name: David Peters
 E-Mail: dpeters@gbww.org
 Date/Time: 2025-02-10 13:17 (Time Zone: -06:00)